



anil datar & associates

STRUCTURAL DESIGNER & INDUSTRIAL CONSULTANTS

7A, N-1, Near St. Xavier-Highschool, CIDCO,
Aurangabad - 431 003. ● Phone 2486294.

Mob.: 9422206947 ● Email. anilsdatar@gmail.com

18th October, 2016

STRUCTURE STABILITY CERTIFICATE

Project : The Jain International School
Location : Jabinda Town, Shahnoorwadi, Aurangabad

Building Details

- Building Structure : RCC Ground + 2 Floors
- Floor Areas : Super Built up area 6879.56 sq.mts
- Height : 12.00 mts.
- Wall thickness : External and internal 200 mm thick and inside partitions 100 mm
- Plastering (inside) : 12 mm thick neeru finish
- Plastering (outside) : 20 mm thick rough plaster

CERTIFICATE

- Building is supported on frame structure with reinforced concrete columns beams and slab which is enough to take the load of the existing structure.
- The beams and reinforcement provided is enough to take the load of the existing structure
- I hereby certify that the building is structurally stable with above structural parameters.
- The above certificate is based on the assumption that reinforcement is provided as per structural drawing provided. It is assumed that the concrete mix used is M-20 for columns and M-20 for slabs as per IS-453-2000


ANIL DATAR & ASSOCIATES



anil datar & associates
Structural designer & industrial Consultants
7A, N-1, Near St. Xavier-Highschool, CIDCO,
A'bad-431 003, Ph-2486294, Mob-9422206947,
Email-anilsdatar@gmail.com, L.No.NRVE/287



PRINCIPAL
THE JAIN INTERNATIONAL SCHOOL
AURANGABAD



anil datar & associates

STRUCTURAL DESIGNER & INDUSTRIAL CONSULTANTS

7A, N-1, Near St. Xavier-Highschool, CIDCO,
Aurangabad - 431 003. ● Phone 2486294.

Mob.: 9422206947 ● Email. anilsdatar@gmail.com

CERTIFICATE OF STABILITY OF STRUCTURE

Date : 16-01-2015

Proposed school building on C.T.S No.29(PART)/30/2 for Shri Narendrasingh Tarasingh & Rajendrasingh Tarasingh Jabinda.

I here by certify that I have personally visits the above existing house and inspected all structural elements of the building.

I am of the opinion that the structure is safe and stable for the purpose for which it is intended.

Provided no change in design and damage externally should be done to the original structure.

ANIL DATAR & ASSOCIATES.

 **anil datar & associates**
STRUCTURAL DESIGNER & INDUSTRIAL CONSULTANTS
7A, N-1, Near St. Xavier - Highschool, CIDCO,
Aurangabad- 431003. Phone-2486294

PRINCIPAL
THE JAIN INTERNATIONAL SCHOOL
AURANGABAD

